



# AIRTHERM

A Mestek Company

Tabulated below is the sound power data fro AIRTHERM Unitaire fan coil units. Riverbank Acoustical Laboratory located in Geneva, Illinois has conducted independent sound power tests for AIRTHERM. The facilities and measurement techniques were in complete accordance with ARI Standard 350-86. The standard output of the ILG Source is that indexed in ASTM E336-67T.

## OCTAVE BAND SOUND POWER RATINGS

(DB RE: 10<sup>-12</sup> WATTS)

UNIT SIZE	MOTOR SPEED	MOTOR RPM	CFM	OCTAVE BAND						
				2	3	4	5	6	7	8
				CENTER FREQUENCY (CPS)						
				125	250	500	1000	2000	4000	8000
021	HIGH	1010	240	52	53	45	43	39	35	34
	MED	950	220	49	50	42	40	36	32	31
	LOW	750	175	44	45	37	35	31	27	26
031	HIGH	1060	310	50	55	49	47	44	37	30
	MED	950	275	47	52	46	44	41	34	27
	LOW	750	220	42	47	41	39	36	29	22
041	HIGH	1060	400	50	52	50	46	42	34	33
	MED	950	350	47	49	47	43	39	31	30
	LOW	750	280	38	44	42	38	34	26	25
061	HIGH	1060	600	53	58	52	51	47	41	37
	MED	950	535	50	55	49	48	44	38	34
	LOW	750	425	45	50	44	43	39	33	29
081	HIGH	1070	800	52	56	51	51	48	39	32
	MED	950	710	49	53	48	48	45	36	29
	LOW	750	560	44	48	43	43	40	31	24
101	HIGH	1070	1060	55	60	53	52	49	42	36
	MED	950	900	52	57	50	49	46	39	33
	LOW	750	710	47	45	45	44	41	34	28
121	HIGH	1220	52	52	57	51	50	46	40	36
	MED	----	----	----	----	----	----	----	----	----
	LOW	800	44	44	49	43	42	38	32	28

FOR HI STATIC MOTORS, ADD 8.5 TO EACH ONE OF THE OCTAVE BAND LEVELS.